

# Progress Report on Shower Calibration and DAQ setup


**Kalyan Allada**

University of Kentucky

Hall-A Transversity Collaboration Meeting. Oct 09, 2007

# Shower Calibration


ADC peak value for shower blocks



- ADC peaks were adjusted to 120 channel
- All channels are working fine


# High Voltage

shower high voltages: new



- pedestals are 5-10 channels wide

# Shower Sum



- software sum vs hardware sum for a (vertical) pair of modules passing the near vertical track cut.

# Shower Sum



## DAQ setup

- Working setup of DAQ with trigger supervisor (any combination of FASTBUS and VME crates) is ready.
- Currently only Bigbite calorimeter is being read
- Chamber II will be connected soon and tested
- SIS 3800/3801: normalization scalers - atleast 32 channels
- Double gating: Target pol = 0 (hel= +, hel= -)  
Target pol = 1 (hel= +, hel= -)
- Test all scalers in the testlab with double gating.
- Other scalers units for diagnostic purposes - need around 100 channels

## Conclusions and work to be done before Dec07

- Cosmic calibration/testing of shower package is complete - looks all fine.
- Basic DAQ setup with trigger supervisor have been setup (minor problems).
- Scalers have to be tested in the testlab – currently working on it.
- Preshower have to be tested/calibrated when it is ready - will be quick, analysis scripts are ready.
- Chamber II have to be tested using FASTBUS readout.

## Thanks to..

- Bob Michaels (for DAQ setup)
- Sergey Abrahamyan (for discussions on shower calibration)
- Xiaodong Jiang
- Brad Sawatzky
- Albert Shahinyan