

Department PHYSICS  
Subject HADRON DIPOLE COG  
Name STEVENS / SPIEGEL  
Address T.J.N.A.F. HAN "A"

National® Brand

## **Computation Notebook**

11 $\frac{3}{4}$ " x 9 $\frac{1}{4}$ ", 4 x 4 Quad., 75 Sheets

**43-648**



0 73333 43648 8



AVERY  
DENNISON  
Office Products  
Chicopee, MA 01022

# HADRON DIPOLE

## QUENCH Protection Circuits

### 1. Megger tests

a. From P2 to J11 CABLE

- 1. VLAP > 999 M $\Omega$
- 2. VLBN > 999 M $\Omega$
- 3. VMAP > 999 M $\Omega$
- 4. VLAN > 999 M $\Omega$
- 5. VMBP > 999 M $\Omega$
- 6. VMAN > 999 M $\Omega$
- 7. VLBP > 999 M $\Omega$
- 8. VMBN > 999 M $\Omega$


### 2. Quench Voltages

(INPUT SIGNALS)

- 1) VLAP - VLAN Loop + 0.071 mv -0.070 mv
- 2) VLBN - VLBP Loop + 0.073 mv -0.068 mv
- 3) VMAP - VMAN Loop + 1.190 v -0.770 mv
- 4) VMAN - VMBN Loop + 1.160 v -1.800 v

9/30/96

Resistance of D.C. cables only in parallel with dump resistor (fast):



$$\left. \begin{array}{l} I = 200A \\ V = 0.20V \end{array} \right\} R_T = R_{F0} // R_{cables} = \underline{\underline{0.00152}} \text{ } \mu\Omega$$

9/30/96 1:30 P.M.

Tested to 2000A with short circuit = No faults, regulators O.K. - $\mu$ J  
Can run for 5 minutes

Notes: Local voltage sense lines #18 & #19 are connected to #79 & #78 respectively.  
This location is the input to the choke, not the output of the choke.

2

10/1/96 3:10 P.M.

Dump resistor (fast) resistance:  $R_{DUMP} = 0.13359$  as determined by Kelvin bridge

coil resistance to ground without power supply:  $R = 100 \text{ m}\Omega @ 250 \text{ VAC}$

Strain Gauges @  $I=0$ ; Bias voltage: 503 mV for both amplifiers, Multiplier = 200

Multiplexor #1, Amplifier #1 (leftmost):

<u>Switch position (channel)</u>	<u>Strain Gauge #</u>	<u>Location</u>	<u>Value @ I=0</u>
1	SG1	EM1	+2
2	SG2	EM2	+80
3	SG3	EM3	+9
4	SG4	EM4	-43
5	SG13	300L	-197
6	SG6	EM6	+3
7	SG7	EM7	-3
8	SG14	300R	-192
9	SG9	670L	+2
10	SG10	600R	-147

Multiplexor #2, Amplifier #2 (rightmost):

<u>Switch Position (channel)</u>	<u>Strain Gauge</u>	<u>Location</u>	<u>Value @ I=0</u>
1 (11)	SG5	EMS	+57
2 (12)	SG8	EM8	+39
3 (13)	SG11	100	-188
4 (14)	SG12	200	-162
5 (15)	SG15	400	+114
6 (16)	SG16	500	-24

- Both amplifiers were calibrated such that they both read the same values for the same strain gauges - one was calibrated against the other with the amplifier balance adjustment.  $\text{--ff}$  (Ch. 11-16 calibrated against Ch. 1-10)

- The amplifiers for Ch. 1-10 was adjusted to produce the maximum number of zero strain on the gauges in combination with the multiplexor balance adjustments.  $\text{ff}$

1. *Leucosia fuscata* (L.)

2. *Leucosia fuscata* (L.)

3. *Leucosia fuscata* (L.)

4. *Leucosia fuscata* (L.)

5. *Leucosia fuscata* (L.)

6. *Leucosia fuscata* (L.)

7. *Leucosia fuscata* (L.)

8. *Leucosia fuscata* (L.)

9. *Leucosia fuscata* (L.)

10. *Leucosia fuscata* (L.)

11. *Leucosia fuscata* (L.)

12. *Leucosia fuscata* (L.)

13. *Leucosia fuscata* (L.)

14. *Leucosia fuscata* (L.)

15. *Leucosia fuscata* (L.)

16. *Leucosia fuscata* (L.)

17. *Leucosia fuscata* (L.)

18. *Leucosia fuscata* (L.)

19. *Leucosia fuscata* (L.)

20. *Leucosia fuscata* (L.)

21. *Leucosia fuscata* (L.)

22. *Leucosia fuscata* (L.)

23. *Leucosia fuscata* (L.)

24. *Leucosia fuscata* (L.)

25. *Leucosia fuscata* (L.)

26. *Leucosia fuscata* (L.)

27. *Leucosia fuscata* (L.)

28. *Leucosia fuscata* (L.)


29. *Leucosia fuscata* (L.)

30. *Leucosia fuscata* (L.)

1/1/96 6:00 p.m.

coil and power supply resistance to ground =  $4.18\text{ m}\Omega$  without prot. Ckt connected  
 $= 40\text{ k}\Omega$  with " "

40 k could be due to the parallel contributions of the  $\sim 20\text{k}$  input impedances seen by the protection circuit (8 or 7 resistors total) to ground. This implies that the protection circuit power supply is referenced to ground.



1. *Leucostoma* *anthracinum* (L.) Pers.  
2. *Leucostoma* *anthracinum* (L.) Pers.

3. *Leucostoma* *anthracinum* (L.) Pers.

4. *Leucostoma* *anthracinum* (L.) Pers.

5. *Leucostoma* *anthracinum* (L.) Pers.

6. *Leucostoma* *anthracinum* (L.) Pers.

7. *Leucostoma* *anthracinum* (L.) Pers.

8. *Leucostoma* *anthracinum* (L.) Pers.

9. *Leucostoma* *anthracinum* (L.) Pers.

10/1/96 FIRST RAMP UP 7

	0	200	400	600	
SG1	+2	+2	+1		
SG2	+80	+80	+80		
SG3	+9	+9	+5		
SG4	-43	-46	-52		
SG13	-197	-197	-198		
SG6	+3	+3	+2		
SG7	-3	-3	-3		
SG14	-192	-190	-183		
SG9	+2	+2	+1		
SG10	-147	-146	-144		
SG5	+57		+59		
SG8	+39		+37		
SG11	-188		-188		
SG12	-162		-164		
SG15	+114		+113		
SG16	-24		-24		

INSTITUTED A FAST DUMP @ 400A.  
 BURNED OUT CONTACTOR ON THE MS.  
 BREAKER. FOUND THE FAST DUMP AND  
 SLOW DUMP RESISTORS WERE REVERSED.

10/2/96 ORDERED NEW BREAKER FROM GE  
 10/4/96 BREAKER RECEIVED AND INSTALLED.  
 CHECKED OUT BREAKER

ATTEMPTED TO POWER IN 400A.  
 TRIP ON NEGATIVE LEAD

10/8/96. DISCONNECTED Power supply  
 RAN IN TO START ALL LOADS 600A.  
 TRIED MEASURING MAGNET  
 INSURANCE, NOT SUCCESSFUL.  
 RAN SUPPLY THROUGH FAST  
 DUMP RESISTOR.



10/2/96

PROTECTION CIRCUIT TEST SUBSEQUENT TO ACCIDENT

$V_{LAP} - V_{LAN}$	=	+ POLARITY + 0.071	- POLARITY - 0.070
$V_{LBN} - V_{LBP}$	=	+ 0.072	- 0.069
$V_{MAP} - V_{MAN}$	=	+ 1.19	- 0.77
$V_{MAN} - V_{MBN}$	=	+ 1.16	- 1.80

10/2/96 -JP

Items checked after M3 failure:

- All 12 SCR's O.K.
- Capacitor bank (except filter) is O.K.
- Slow Discharge (free-wheeling) diodes O.K.
- Protection circuits O.K. as noted above.
- Insulation test of magnet:  $R > 2 \text{ M}\Omega$
- Ran power supply through fast dump resistor and measured  $0.134 \Omega$  at  $V=8\text{V}$ ,  $I=60\text{A}$

Insulation test of magnet with protection circuit:  $R = 110\text{k}$ .

Resistance to ground through protection circuit was previously  $40\text{k}$ . The  $110\text{k}$  is the contribution by only the warm end lead voltage taps ( $\pm$ ). The  $110\text{k}$  remains the same if the internal voltage taps are connected or not. It appears after further testing that the voltage taps inside the magnet. When we turn on the power supply to the magnet, we immediately see a lead voltage fault and a lead voltage of several hundred millivolts. This is evidence that one lead voltage tap (cold end) is floating (disconnected), while the warm end tap is at power supply output potential. -JP

1. *Thlaspi arvense*  
2. *Thlaspi arvense*  
3. *Thlaspi arvense*  
4. *Thlaspi arvense*  
5. *Thlaspi arvense*  
6. *Thlaspi arvense*  
7. *Thlaspi arvense*  
8. *Thlaspi arvense*  
9. *Thlaspi arvense*  
10. *Thlaspi arvense*


October 7, 96 Monday

1015 Set up zero current on strain  
gauges.

SG 1	2.	EM 1
2	79	EM 2
3	11	EM 3.
4	-39	EM 4
13	5 -197	300L
6	5	EM 6
7	0	EM 7
14	8 -188	300R
9	3	600L
10	-143.	600R

SG 11	57
12	36
13	-189
14	-163.
15	110
16	-22.


Connections on 1st  
column switchboard.




Actual wiring

October 8, 1992

13



Connections on E12



Power Supply

Dump

HANNON ARM

Connections on 1/12



10/21/96

DISMANTLING OF CONNECTORS J-2 & J3 ON THE HADRON  
DIPOLE CRYOSTAT.

A GENTLE PURGE WAS ESTABLISHED TO PREVENT WATER BACK-MIGRATION INTO THE CRYOSTAT HELIUM VESSEL. J-2 WAS REMOVED AND THE CABLE PULLED OUT TO FACILITATE INSPECTION OF THE INTERIOR SIDE OF THE CONNECTOR AND THE SHORT LENGTH OF CABLE ATTACHED TO IT.

CLOSE INSPECTION REVEALED THAT THE WIRES ATTACHED TO J2 PINS M AND N SUFFERED SEVERE DAMAGE, WITH ONE WIRE VIRTUALLY VAPORIZED, AND THE OTHER WIRE BRITTLE, BURNED AND SO DELICATE THAT IT BROKE WHEN TOUCHED & MOVED. ALL WIRES ON BOTH CONNECTORS ARE 16 GA. SOLID LAQUERED "MAGNET" OR "COIL" WIRE. PINS M. AND N # WERE MELTED/ VAPORIZED ON THE BACK OF THE CERAMISEAL CONNECTOR, LEAVING A FLAT "PUDDLE" OF SLAG ON THE CERAMIC IN THE AREA OF THE PINS. THE SLAG PUDDLE IS ABOUT 1/4" IN DIAMETER, AND EXTENDS TO THE METAL HOUSING OF THE CONNECTOR. A THICK DEPOSIT OF BLACK SOOT IS ON EVERYTHING. THE WIRES ARE WRAPPED WITH A NYLON "SPIRAL" TUBE, WHICH WAS PARTIALLY MELTED ON ITS END CLOSEST TO J2. THERE IS NO VISIBLE DAMAGE TO ANY WIRES ON J3. DR. WANG'S WIRE LABELS ARE STILL ON EACH WIRE, BUT THEY DO NOT CORRESPOND TO THE CONNECTOR PINS "A, B, C, ETC.", SO I AM INSTALLING NEW LABELS #1 THROUGH #26, AS I DETACH EACH WIRE FROM THE CONNECTOR.

J2:

{ A - 1	R - ⑬
{ B ✓ 2	S ✓ 14
{ C ✓ 3	T ✓ 15
D ④	U ✓ 16
E ✓ 5	V ✓ 17
F ✓ 6	W ✓ 18 - NO HEAT SHANK
G ✓ 7	X ✓ 19
H ✓ 8	Y ✓ 20 - TWO WIRES
J ✓ 9	Z ✓ 21
K ✓ 10	a ✓ 22
L ✓ 11	b ✓ 23
M ✓ NO WIRE 49	c ✓ 24
N ✓ NO WIRE 50	
P 12	

~~THREE WIRES  
FOUR~~

J3:

A - NO WIRE	R ✓ 37
B - NO WIRE	S ✓ 38
C - ⑤	T ✓ 39
D ⑥	UV 40
E ⑦	V ✓ 41
F ⑧	W ✓ 42
G ✓ 29	X ✓ 43
H ✓ 30	Y ✓ 44
I ✓ 31	Z ✓ 45
K ✓ 32	a ✓ 46
L ✓ 33	b ✓ 47
M ✓ 34	c ✓ 48
N ✓ 35	
P ✓ 36	

Loca  
Cant

Ren  
Can

11/26/96, 2:10 P.M.

- Dynapower is connected in short-circuit at cryostat and isolated from ground.

- Set regulator jumpers to: ZFCT, short circuit

- Crow bar set to 800 A.

- Turned p/s on to 600A & appeared to be stable;  $V=0.53V$ ;

- Set p/s to remote

*Local control*

- Brought I to 550 A in 100A steps. At each transition, the output oscillated at  $\pm 5\%$  and decayed to  $\sim 2\%$  of setpoint and oscillated around setpoint.

- Output voltage waveform looks good - no missing pulses or erratic firing.

- Set up regulators for short feedback, short circuit.

- \* - Set crow bar for 2000 A.

- Power supply ~~works~~ regulates well with shunt short circuit mode ~~on~~ - ran to 1800 A. to ~~the problem~~. Output voltage waveform is ~~good~~ O.K.

- Replaced regulator with E.A. regulator.

- E.A. regulator works O.K. at ZFCT, short-circuit mode

- " " ~~works~~ work in shunt, short-circuit mode - Act identically to Hadron arm regulator, except for an offset.

- Set E.A. regulator to ZFCT, short circuit

$\rightarrow$  - Operated in remote to 1800 A & regulated O.K.

- Operated in remote with shunt short circuit setting to 1800 A & regulates O.K.

- Put in H.A. regulator, set to ZFCT short Ckt; operated in remote; regulation is erratic. - problem is with regulator board

- Set H.A. regulator to shunt short circuit; operated in remote; operated to 1800 A, regulates O.K.

Note: Voltage output waveform indicates that one cycle is dropped at 1800 A. The effect is greatly reduced at 1200 A and disappears at 1000 A.

- Set regulator to ZFCT, short circuit,

- Set crow bar to 800 A.

- Set control to local

- Current leads are now isolated from ground & disconnected from magnet & isolated from each other.

- Test for presence of dump resistor:

Set regulator for test mode, shunt short circuit

Set  $V=10V$ , Increase I until  $V=10V$  on meter

measure I of one lead of tag dump resistor with clamp-on ammeter:

$$\text{Q} V = 10.05V, I = 15.1A \quad R = \frac{10.05V}{15.1A \cdot 5} = \underline{\underline{133.1 m\Omega}}$$

This agrees with  $R=133.6 m\Omega$  as measured by Kelvin bridge

1. *Amphibolite*

2. *Quartzite*

3. *Schist*

4. *Metavolcanic rock*

5. *Metavolcanic rock*

6. *Metavolcanic rock*

7. *Metavolcanic rock*

8. *Metavolcanic rock*

9. *Metavolcanic rock*

10. *Metavolcanic rock*

11. *Metavolcanic rock*

12. *Metavolcanic rock*

13. *Metavolcanic rock*

14. *Metavolcanic rock*

15. *Metavolcanic rock*

16. *Metavolcanic rock*

17. *Metavolcanic rock*

18. *Metavolcanic rock*

19. *Metavolcanic rock*

20. *Metavolcanic rock*

21. *Metavolcanic rock*

22. *Metavolcanic rock*

23. *Metavolcanic rock*

24. *Metavolcanic rock*

25. *Metavolcanic rock*

26. *Metavolcanic rock*

27. *Metavolcanic rock*

28. *Metavolcanic rock*

- Measure I through slow dump resistor with M4 closed :  
 $I = 0.1A \rightarrow$  diodes are reverse biased.  
 $I_F = 0.1 \cdot 5 = 0.5A$

- Set regulator to Normal operation, ZFC feedback.
- Insulation test to ground of p/s outputs at 250 VDC :  $R = 31\text{ M}\Omega$
- Insulation test to ground of magnet:  
 with perfectida circuit :  $0.84\text{ M}\Omega$   
 without " " :  $0.11\text{ M}\Omega$

11/27/86 1:30 A.M.


- After cleaning J2 with isopropanol, resistance to ground of magnet without quench detector electronics or p/s is  $11\text{ M}\cdot\Omega$
- Insulation test of magnet + p/s @ 250 VDC :  $R = 6.8\text{ M}\Omega$  to ground
- Test of ~~magnet~~ voltage interlocks:  
 VLAP-VLAN : +71mV, -70mV  
 VMAP-VMAN : +1.19V, -770mV  
 VMAN-VBN : +1.67V, -1.81V  
 VLBN-VLP : +69mV, -74mV
- All faults open M3 and M4 for a fast dump
- Test of cable interlock @ cryostat. ; removed J2 at cryostat; M3 + M4 opened for a fast dump & cable interlock light were out.
- Tested lead flow faults - lead 1 or lead 2 opens M3 + M4 for a fast dump  
 Lead #1 trip point : 40 SLM  
 Lead #2 " " : 40 SLM
- Tested He level trip : M3 + M4 opened for fast dump.  
 Set He level trip point to 60%

- Set V=2.0V, I=100A, turned on p/s.
- current did not stop at regulation setpoint - need to check jumpers on regulator.
- STOP + emergency STOP open M3, but close M4 always
- Tested slow dump (first) then fast dump time constants, and inductances :  $L = 3.26\text{ H}$ ,  $T_{50} = 260-280\text{ sec}$   
 $T_{20} = 23\text{ sec.}$

12/4/86 10:30 A.M.

- Found jumper J10 was installed instead of J1
- p/s now regulates very well at established setpoints.
- Put E.A. p/s PLC in H.A. p/s - all problems associated with stop buttons and M4 went away & now works correctly. Need to copy E.A. PLC program to H.A. PLC.

20




$$IR = \rho \frac{L}{A} I$$

$$I = I_0 e^{-\frac{t}{\tau}} \quad -\frac{t}{(\ln |I| / I_0)} = \tau$$

## Stain Gages

## Stain Gages

Stain Gages



12/4/96

- Strain Gauges:
  - Ch1 + Ch2 bridge excitation set to ~~503~~ 503 mV
  - Did not change amplifiers zero or balance
  - Did not change multiplier balance.

### MULTIPLEXER #1      AMPLIFIER #1

CHANNEL	STRAIN GAUGE	LOCATION	VALUE F=0 12/4/96	12/6/96
1	SG1	EM1	+21	0
2	2	2	+96	127
3	3	3	+28	58
4	4	4	(-25)	-42
5	13	300L	(-187)	-191
6	6	EM4	+23	16
7	7	7	+16	-1
8	14	300R	(+169)	-189
9	9	600L	+22	0
10	10	600R	(-127)	-146

### MULTIPLEXER #2      AMPLIFIER #2

CHANNEL	STRAIN GAUGE	LOCATION	VALUE F=0 12/4/96	12/6/96
1	SG5	EM5	+56	59
2	8	8	+35	37
3	11	100	(-189)	-189
4	12	200	(-164)	-164
5	15	400	+111	114
6	16	500	(-25.)	-25

1:20 Am: See  $I=200A$ ,  $V=2.0V$  : Lead A: 68.0 SCAN  $\frac{3.4mV}{2.6mV}$ ; ZFACT = 1.0008; Panel: 200A, 0.19V  $\Sigma I = 15.25A / 200A = 0.0758$ ;  $\Sigma V = 9.84V / 15.25A = 0.64V$  (2975)

CHANNEL	STRAIN GAUGE	LOCATION	L = 0.134 - 22.4H $R_s = \frac{3}{2975} = 10m\Omega$
1	SG1	EM1	
2	2	2	+21
3	3	3	+96
4	4	4	+28
5	13	300L	(-29)
6	6	EM4	(-187)
7	7	7	+16
8	14	300R	+16
9	9	600L	(-167)
10	10	600R	(+22) (+125)



(C) 200A set

12/4/9c

1	SG 5
2	8
3	11
4	12
5	15
6	16

1	E1115
2	8
3	100
4	200
5	2/00
6	500

1	+ 57
2	+ 36
3	(- 189)
4	(- 163)
5	(- 111)
6	+ 24

- Set  $I = 400A, V = 4.0V$ 

Lead A: 68 SLM, 6.8 mV

Lead B: 62 SLM, 5.5 mV

ZFACT = 2.00008V

 $I = 400A, V = 0.37V$  $\tau_s: 400A - 390A : 9.84s \quad \tau = 388 \text{ sec.}$  $\tau_f: 240A - 100A : 20.12s \quad \tau = 22.98 \text{ sec.}$ 

1	57
2	36
3	(- 189)
4	(- 164)
5	- 111
6	(- 22)

- Set  $I = 600A, V = 4.0V$ 

Lead A: 68.5 SLM, 10.1 mV

Lead B: 63.3 SLM, 8.3 mV

ZFACT: 3.00010V

 $I = 600A \quad V = 0.55V$  $\tau_s: 600A - 590A : 7.34s, \quad \tau = 397.3 \text{ sec.}$  $\tau_f: 555A - 200A : 23.12s, \quad \tau = 22.65 \text{ sec.}$ 

1	61
2	35
3	(- 189)
4	(- 164)
5	111
6	(- 24)

- Set  $I = 800A, V = 6.0V$ 

Lead A: 69.8 SLM, 13.3 mV

Lead B: 64.4 SLM, 11.1 mV

ZFACT: 4.00004V

 $I = 800A \quad V = 0.73V$  $\tau_s: 800A - 780A : 11.68 \text{ sec.} : \tau = 419.9 \text{ s}$  $\tau_f: 735A - 300A : 19.23 \text{ sec.} : \tau = 21.46 \text{ s}$ - Set  $I = 1000A, V = 6.0V$ 

Lead A: 71.0 SLM, 16.4V

Lead B: 65.5 SLM, 13.9V

ZFACT: 5.00006V

 $I = 1000A \quad V = 0.94V$  $\tau_s: 1000A - 970A : 13.71s \quad \tau = 409.8 \text{ sec.}$  $\tau_f: 920A - 300A : 23.53s \quad \tau = 21.0 \text{ sec.}$ 

$$R = \frac{2.8114}{409.8 \text{ sec.}} = 6.8 \text{ mV/V}$$

$$L = 2.81 \text{ H}$$



- Set  $I = 1200A$ ,  $V = 6.0v$

Lead A: 71.3 SCFM, 18.7 mV

Lead B: 66.4 SCFM, 16.8 mV

ZFCT: 6.00025V

$I = 1204A$   $V = 1.09v$

$\tau_s: 1204A - 1160A; 14.4s \quad \tau = 386.8s$

$\tau_f: 1160A - 900A; 20.31s \quad \tau = 20.08s$

- Set  $I = 1400A$ ,  $V = 6.0v$

Lead A: 78.1 SCFM, 20.9 mV

Lead B: 72.2 SCFM, 18.9 mV

ZFCT: 7.00077V

$I = 1405A$   $V = 1.28v$

- Set  $I = 1600A$ ,  $V = 6.0v$

Lead A: /

Lead B: /

ZFCT: /

$I = /$   $V = /$

$$\tau = -\frac{t}{\ln|\frac{\tau_s}{\tau_f}|}$$

{  $\tau_s: 1445A - 1350A, 22.04sec : \tau =$

{  $\tau_f: 1200A - 900A, 40.04sec : \tau = \underline{22.41s}$

12/5/96.

Raised current to 1000A. Setting at flat  
value for past 15 minutes.

SG's #2	1	78
	2	42
	3	-189
	4	-164
	5	111
	6	-23

Similar to earlier  
data

Other strain gauges  
on computer tracking  
yesterday's data.

We heard a noise, twice, last night at  
about 1500A. We checked 5 strain gauges  
but could see nothing. Values are  
considerably below what we had for  
deplete #1. Noise could be attributed  
to vacuum tank moving relative to the  
mon.

26

12-5-96.

Up to 1000A there does not appear to be any shifting or settling of loads. Concern over ability strain gauges indicate lower values.  
 I have attached the data from last night

At 1000A how can compare the hadron arm magnet to the electron arm

	HA	FA	A Factor
EM1 SG1	0.042 T	0.511 T	10
EM2 SG2	0.8236 T	0.12 T	- factor 7.
EM3 SG3	0.5663 T	3.57 T	factor 7
EM4 SG4	0.2707 T	1.03 T	factor 4.

Even if one makes for allowances these loads are small compared to the capacity of the loads

At 1500A.

	HA	FA	factn.
EM1	0.273 T	1.456 T	6
EM2	1.392 T	2.23 T	+ 2
EM3	1.062 T	6.11 T	6
EM4	0.6132 T	2.85 T	+ 5.

We will increase current slowly and watch strain gages.

28

12-6-96.

Yesterday we discovered that the supply transfer line had an excessive ramming pressure ~ 300° mmHg. We changed the mechanical pump but it didn't improve. It added a 60 l/s turbo and the rammer is now down to 17 m/s. And the ice which had formed on the line is gone. We can now test.

We also changed the zeros on the strain gauges late on 12/4/96. Because of my concern that the loads were so low. The strain gauges at zero current have returned to their earlier values.

Unit 1

SG1	EM1	0
SG2	EM2	127
SG3	EM3	58
SG4	EM4	-42
SG13	300L	-191
SG6	EM6	16
SG7	EM7	-1
SG14	300R	-189
SG9	600L	0
SG10	600R	-146

Unit 2.

SG 5	59
SG 8	37
SG 11	-189
SG 12	-164
SG 15	114
SG 16	-25.

04/11/2011

12/6/90

Poured magnet up to the 1500A line and checked first clamp. When we did this the low gauge at the bottom dropped acting like there was a warm pocket at the bottom of the magnet. The temperature sensor at the bottom Tp 26 also increased from 16 (4K) K to 26K? Heat flows also increased as the pressure built up to 1.8 ATM. This was so bad that we were requested to stop so that we wouldn't trip off Hall B.

High heating can be attributable to eddy currents and/or some local heating in the magnet. When they moved the other day (note that we heard) something could be moving in the field causing heating. ?? We don't know.

After discussing with Harry Cardman and John O'Meara we decided to continue testing.

Attempted to pour to low values ~1000A so that J. LeRoux could measure his Hall probe. Magnet supply and levels also dropped - same effect as at 1500A only lesser in extent.

Jones and I checked insulation resistance to ground with a meter and saw megohms. We then got the megger (250V) and measured ~ $\frac{2}{3}$ K ohm. This could be the commutator which we will check.

We tested the trip points they haven't changed! So why magnet tripped is not clear.

We connected the center tap ground on the power supply. If there is heating due to resistance to ground we thought this would lower the voltage - hence the heating.



12/6/86, 4:00 A.M. - 28

- Earlier, p/s had difficulty charging to 1000A because of intermittent ground faults. I cleared the voltage control potentiometer and the noise was reduced. I slowly increased voltage from zero to 6V, and a quench showed up after 600A. This problem, and the apparent He vessel heating can be due to a resistive short to ground in the coil, of sufficiently low resistance to deliver several watts into helium at only 600A. - The level ~~on~~ bottom probe did not drop at 600A discharge.
- Resistance to ground of p/s and magnet: 0.21 MΩ (without protection ch+)
- Resistance to ground of p/s and magnet with all sig instrument cables disconnected except top He level probe: 0.04 MΩ
- Replaced all instrument cables:  $R = 0.21 \text{ mΩ}$
- Installed protection circuit fast box at cryostat ~~exit~~ connectors.
- Verified that quench and lead trip paths have not changed.
- Charged magnet to 100A @ 1.0V, and saw asymmetry in magnet voltage between coil A and coil B:

$$V_{MAP} - V_{MAN} = 0.75 \text{ V}$$

$$V_{MAN} - V_{MBN} = 0.25 \text{ V}$$

Also measured to ground:

$$V_{LAP} - GND:$$

$$V_{LBN} - GND:$$

Measurements were made with dump resistor center tap resistor disconnected and ground fault circuit off

- Switched on dump resistor center tap resistor (10kΩ, SW) to ground. Magnet voltages are unchanged.  $V_{LAP}-GND$  and  $V_{LBN}-GND$  are now 0.5V when charging at 1.0V.
- Adjusted R34 on quench protection circuit to balance the protection circuit with the magnet so that "VMD" signal is zero on the magnet charge-up. Could not bring to zero, but reduced effect by 50%. R34 was originally centered. Balance adjustment had no obvious effect on quench faults. May try to increase R34 from 10k to 50k tomorrow to improve balance.
- 

(coil A: 730 SCm  
coil B: 770 SCm  
at discharge.)

34

12/7/96

- Inductance measurement @  $V = 1.00$  :
- charge time: rise of 20A in 12.45 sec:

$$V = L \frac{dI}{dt} : L = V \frac{dt}{dI} = 1.0 \frac{12.45}{20A} = \underline{0.621H}$$

Slow discharge: 40A - 25A in 10.11 sec

$$I = I_0 e^{-\frac{t}{T}} : \tau = \frac{-t}{L_0 / I_0} = \frac{-10.11}{L_0 / \frac{25A}{40A}} = \underline{21.5 \text{ sec}}$$

$$\tau = \frac{L}{R} : L = \tau \cdot R = 21.5 \cdot 10m\Omega = \underline{0.221H}$$

- Will measure with chart recorder at higher currents.

$$35A - 5A = 10.78s$$

$$\tau_{sp} = \underline{38.8 \text{ sec.}} \quad \underline{100A \cdot 35A} \quad \underline{31 \text{ sec}}$$





~~12/7/96~~

36

10  
e

12/09/96.

I



1). Check instrumentation circuit.

✓ 2). measure coil resistances

3). Disconnect everything and measure coil inductance

✓ 4). Measure inductance of coil by the up and down ramping.

✓ 5). Check supply regulation by at self

10KV  
100A  
100V  
(c)

Measure ground fault current ramping and ramp down. So as apparent ground fault charge with ramping

7). Measure fault EA &amp; I/R



12/9/96Set  $I = 150A$ ,  $V = 0.32V$  regulated

$$V_A = 78mV, V_B = 98mV$$

V<sub>A</sub> dropped from 90mV to 78mV in ~1 minute  $V_{panel} = 0.33V$ V<sub>B</sub> dropped from ~130mV to 98mV in ~2 minutesAfter 20 min,  $V_A = 16mV, V_B = 16mV$ 

- There appears to be shorting of windings on back balance of the coil at the bottom of the magnet. A charge or discharge voltage will produce a 1V across the shorted copper and a current will flow. As the regulator approaches its saturation, the magnet p/s AV will approach 2.00. The coil winding 1V will reduce and the current that was previously circulating through the shorted copper will begin to circulate through the magnet until the coil is ~fully charged. The charge and discharge time constants will reflect the effects of the shorted copper. A field measurement will indicate if the magnet still functions properly.

- After 20 minutes,  $V_A = -3mV, V_B = 3.1mV$

Panel:  $I = 150A, V = 0.15V$

~~12/9/96~~

- Found lock on NMR:  $B = 0.16613 T$  and slowly rising

- going to 200A for weaker field reading.

- @  $I = 200A, V_A = 73mV, V_B = 90mV$

Panel:  $V = 0.34V, I = 200A$

- after 10 min @ 200A:  $V_A = 30.8, V_B = 39.3mV, V_{panel} = 0.26V, I = 200A$ .


After 25 min @ 200A:  $V_A = 13mV, V_B = 16.4mV, V_{panel} = 0.22V, I = 200A$

~ 45 ~  $V_A = -4.3mV, V_B = 6.9mV, V_{panel} = 0.20V, I = 200A$

- Slowly discharged magnet to 20A

- placed ammeter between 100A, 5W decay resistor center tap and ground

- charged magnet to 100A.

regulating @ 100A,  $I_G = 0.0mA DC$  

-  $I_G = 0$  for charging and discharging.

- See R39 balance adjustment to center and attempted to balance by adding ~~or~~ a shunt resistance across R39.



- A given balance for one voltage does not apply to another changing voltage.
- The oscillations occurring during regulation still trip P/S regardless of how well balanced it is. This variable balance may be due to the effects of the internal shorts of windings.
- Try using only diodes for slow dumps - may reduce effect of negative voltage regulation.

12/10/86

- Disconnected p/s from magnet to test current into dump res. 200Ω.
- Resistance to ground of P/S outputs only @ 250 VDC:  $R = 46.5 \text{ M}\Omega$
- " " " " magnet only @ 250 VDC:  $R = 0.11 \text{ m}\Omega$  without prot. elec.  
 $R = 0.04 \text{ m}\Omega$  with prot. chf.
- Set regulator to short short circuit, see feedback to shunt
- Set  $V = 100\text{v}$
- @  $V_{out} = 100\text{v}$ ,  $I = 15\text{A}/\text{terminal} \cdot 5\text{ terminals} = 75\text{A}$

$$\frac{100\text{V}}{75\text{A}} = \underline{0.133 \text{ m}\Omega}$$

$$V = \frac{A}{C \cdot \rho \cdot L}$$

- Charged regulator to ~~short~~ 2FCT short circuit, 7FCT feedback
- bolted together cables at magnet & isolated from ground for short-circuit test.
- Set  $V = 1.0\text{v}$ ,  $I = 0$
- @  $I = 200\text{A}$ ,  $V = 0.18\text{v}$   $R = 0.9 \text{ m}\Omega$
- Hunted up Lakeshore p/s to dipole with #10 cable
  - Set  $V = 5.0\text{v}$
  - turned off ramp control and I step limit
  - Set  $I_{MAX} = 125\text{A}$ ,  $V_{MAX} = 10.0\text{v}$ .
  - Set up chart recorder on magnet coils A + B  
 $I = 0.40\text{A}, 10\text{s}, V = 3.1\text{v} \quad L = 0.78\text{H}$   
 $\text{@ } I = 100\text{A}, V = 2.08\text{v}$  drop along cable
- Operated E.A. dipole w/ Dynapower pls at 200A. Turned up current from 150A to 200A by hand in current regulation mode.
  - Time constant for coil A and coil B voltages approaching zero is much smaller.
  - " " " " B-field to approach stability is much smaller
  - noise is seen on both coils A + B, while it is seen only on coil A on the H.A. dipole.
  - recorded coil A + coil B voltages with chart recorder.
  - H.A. coil B was measured to have ~25% of the charging voltage, which may indicate more ~~at~~ shorted windings. This may also act as less of an antenna for noise.



12/11/96



- Set up chart recorder on H.A. dipole coil A & coil B w/ Lashbrook p/s to measure charge & discharge times to 100A.
- charging at 3.0v, Discharging at 3.0v. (Actual = 3.07v)
- Set  $V_{set} = 30.0\text{v}$ ,  $I_{set} = 100\text{A}$ . - no heating noticed
- Set up chart recorder for Lashbrook voltage and current outputs. & recorded charged discharge times.
- Disconnected Lashbrook p/s &
- Measured magnet inductance with HP LCR meter Model # 4263B
  - freq = 100Hz @ 1V
  - 2-wire leads
  - Set to parallel resistance & inductance model.
- measured  $V_{MAP}-V_{MAN}$  at breakout box - ~~feedthrough inductance~~ = inductance  
~~estimated around 200mH, with noise.~~  $L = 420\text{mH}$ ,  $R = 29.7\Omega$
- measured across terminals at magnet:  $L = 39.1\text{mH}$ ,  $30.2\Omega$ .
- Kelvin bridge measurement of magnet resistance measured at magnet terminals:  $R = 0.0183\Omega$ , with fluctuations.
- measured inductance again:
 

Set average to 32, medium sampling rate

$V_{MAP}-V_{MAN} = \sim 200\text{mH}$ ,  $R_p = \sim 256\Omega$

$V_{MAP}-V_{MAN} = \sim 200\text{mH}$ ,  $R_p = \sim 262\Omega$

$V_{MAN}-V_{MBN} = \sim 2.7\text{mH}$ ,  $R_p = \sim 1.8\Omega$
- Set up chart recorder to measure  $V_{MAP}-V_{MAN}$ ,  $V_{MBP}-V_{MBN}$  (no joint) and found no difference in response compared to  $V_{MAP}-V_{MAN}$ ,  $V_{MAN}-V_{MBN}$ .
- also looked at  $V_{MAN}-V_{MBP}$  with Fluke 79 voltmeter on 300mV scale, during charge, regulation, and discharge, and found the voltage to be always  $2.0\text{mV}$ . - there is no voltage drop across the center joint.



12/12/96

- charge magnet to 100A w/ LakeShore & monitor tap voltages:
- Set  $I = 100$ ,  $V = 2.0$  V.

- @  $I = 0$  :

$$\begin{aligned} VLAP - VLAN &= 0.0 \text{ mV} \\ VLAP - VMAP &= 0.0 \text{ mV} \\ VLAN - VMAN &= 0.0 \text{ mV} \\ VMAN - VMBP &= 0.0 \text{ mV} \\ VMBN - VLBP &= 0.0 \text{ mV} \\ VLBP - VLBN &= 0.0 \text{ mV} \\ VLBN - VLBN &= 0.0 \text{ mV} \end{aligned}$$


+ @  $I = 100$  A : (lead A: 54.8 SLM, lead B = 53.8 SLM)

$$\begin{aligned} VLAP - VLAN &= 2.1 \text{ mV} \\ VLAP - VMAP &= 2.1 \text{ mV} \\ VLAN - VMAP &= 0.0 \text{ mV} \\ VMAN - VMBP &= 0.0 \text{ mV} \\ VMBN - VLBP &= 0.0 \text{ mV} \\ VMBN - VLBN &= 1.8 \text{ mV} \\ VLBP - VLBN &= 1.8 \text{ mV} \end{aligned}$$

(lead A = 55.0 SLM, lead B = 53.9 SLM)

- @  $I = 100$  A, 90 min. after start :

$$\begin{aligned} VLAP - VLAN &= 1.9 \text{ mV} \\ VLAP - VMAP &= 1.9 \text{ mV} \\ VLAN - VMAP &= 0.0 \text{ mV} \\ VMAN - VMBP &= 0.0 \text{ mV} \\ VMBN - VLBP &= 0.0 \text{ mV} \\ VMBN - VLBN &= 1.7 \text{ mV} \\ VLBP - VLBN &= 1.7 \text{ mV} \end{aligned}$$



$\checkmark$   $VMAP - VMBN = \sim 3.0 \text{ mV}$  noisy  
 $\checkmark$   $VLAP - VLBN = \sim 6.0 \text{ mV}$  noisy  
 $VMAP - VMAN = \sim 1.5 \text{ mV}$  noisy  
 $VMBP - VMBN = \sim 1.8 \text{ mV}$  not noisy ( $\sim 0.1 \text{ mV}$ )



$V_{LAP} - Gnd$  : 27.5 mV  
 $V_{LAN} - Gnd$  : 26.5 mV  
 $V_{MAP} - Gnd$  : 26.0 mV  
 $V_{MAN} - Gnd$  : 25.0 mV  
 $V_{MBP} - Gnd$  : 26 mV  
 $V_{MBN} - Gnd$  : 26 mV  
 $V_{LBP} - Gnd$  : 26 mV  
 $V_{LBN} - Gnd$  : 27 mV

Lead A: 53.6 s/cm, Lead B: 52.3 s/cm

12/13/96

- Warmed up magnet from 16K to 24K
- Installed Hall probe between man probes
- See up chart recorder for coils A + B
- Set  $V = 10.0$  V,  $I = 50.0$  A.
- From 0-50A, took 5.0 sec. @ 10.0 A
- Voltages stabilized very quickly  
 @  $I = 50.02$  A,  $V = 1.54$  V, 12 min. after start.  
 Coil A = 315 mV ( $V_{MAP} - V_{MAN}$ )  
 Coil B = 259 mV ( $V_{MBP} - V_{MBN}$ )

- @ $I = 0$ :	$V_{LAP} - V_{LAN} = 0.0$ mV	$@ I = 50A$ :	3.2 mV
	$V_{LAN} - V_{MAP} = 0.0$ mV	45 min.	-0.1 mV
	$V_{MAP} - V_{MAN} = 0.0$ mV		343 mV
	$V_{MAN} - V_{MBP} = 0.0$ mV		0.1 mV
	$V_{MBP} - V_{MBN} = 0.0$ mV		280 mV
	$V_{MBN} - V_{LBP} = 0.0$ mV		-0.1 mV
	$V_{LBP} - V_{LBN} = 0.0$ mV		3.3 mV

measured w/ Fluke 79 DMM.

After 45 min : P/S  $I = 50.02$  A,  $V = 1.60$  V

$$V_{MAP} - V_{MAN} = 343 \text{ mV}$$

$$V_{MBP} - V_{MBN} = 280 \text{ mV}$$

$$V_{LAP} - Gnd = 345 \text{ mV}$$

$$V_{LAN} - Gnd = 341 \text{ mV}$$

$$V_{MAP} - Gnd = 341 \text{ mV}$$

$$V_{MAN} - Gnd = 10 \text{ mV}$$

$$V_{MBP} - Gnd = 13 \text{ mV}$$

$$V_{MBN} - Gnd = -255 \text{ mV}$$

$$V_{LBP} - Gnd = -255 \text{ mV}$$

$$V_{LBN} - Gnd = -255 \text{ mV}$$



- Set  $I = 100A$ ,  $V = 10.0V$   $V = 5.0V$
- Set up chart recorder for  $B_{Gauss}$  vs.  $I_A$

at 100 Amps

$$VLAP - VLBN = 6.6 \text{ mV}$$

$$VLAN - VMAP = -0.4 \text{ mV}$$

$$VMAP - VMAN = 948 \text{ mV}$$

$$VMAN - VMBP = 0$$

$$VMBP - VMBN = 756 \text{ mV}$$

$$VMBN - VLBP = 0$$

$$VLBP - VLBN = 7.2 \text{ mV}$$

ramped up to 100 from 50

$$V_{max} = 5V$$

ramped down to 0 from 50



ramped up 0 to 100

ramped down 100 to 0

12/16/96

- Filled magnet & set up chart recorder for  $B$  vs.  $I$  using previous settings.
- Turn on LakeShore,  $I = 100A$ ,  $V = 5.0V$  at ~14:50
- Ramped down to  $I = 0$  ~ 17:03

12/17/96

- 9:10 A.M. - Gaussmeter reads 6.43 mT and still dropping. from ~17 mT @ 18:30 yesterday.
- Disconnected LakeShore pls & attaching Dynegage pls to magnet
- Resistance of slow discharge circuit?  
Shorting cables only: ~~0.1051 mΩ/cable~~ =  $0.0826 \text{ mΩ}$  for 2 cables in parallel
- ramped to 200A by hand
- Slow decay resistance time constant seems to be dominated by diode resistance.  
The n/s appears to go into regulation faster, but still trips out quench circuit (but not lead circuit) at ~100A.
- Reached 200A @ 11:30 A.M.
- 6:00 P.M. - AFTER 6½ HOURS AT 200A THE VOLTAGE ACROSS COIL "A" FLOATS FROM +2 TO -1 mVDC, WHILE THE VOLTAGE ACROSS COIL "B" IS +0.2 mVDC, ± 0.2 mV.  
WHEN VIEWED ON AN O-SCOPE, THE TWO VOLTAGES APPEAR TO BE OUT OF PHASE  $\approx 30^\circ$ . WHEN READ AS AN A/C VOLTAGE BY THE FLUKE METERS, I SEE 600 mVAC ON COIL "A", AND 5 mVAC ON COIL "B".

12/17/96 (CONTINUED)

6:17 P.M. - DURING RAMP-DOWN OF THE DIPOLE I OBSERVED AN ODD PHENOMENON: I WAS RAMPING DOWN AT  $-0.7\text{ V}$  AND PASSED  $80\text{ A}$  WHEN I NOTICED THAT THE VOLTAGE METER NO LONGER FLUCTUATED WITH MY INCREMENTAL ADJUSTMENT OF THE CURRENT POTENTIOMETER, BUT RATHER WAS "STUCK" AT  $-0.7\text{ V}$ . I STOPPED TURNING THE POTENTIOMETER AND WATCHED THE CURRENT FIRST FALL BELOW ~~60A~~  $60\text{ A}$  AND THEN SLOWLY INCREASED - BY ITSELF - TO  $81\text{ A}$ , AND THEN STARTED BACK DOWN. WHEN IT AGAIN DRIFTED BELOW  $60\text{ A}$  I LOOKED AWAY TO WRITE THESE NOTES AND A FEW MOMENTS LATER THE QUENCH PROTECTION CIRCUIT TRIPPED AND BEGAN A FAST DUMP. DURING THE TIME THE VOLTAGE WAS "STUCK" AT  $-0.70\text{ V}$ , I OBSERVED  $0.731\text{ VDC}$  ACROSS THE SLOW-DUMP RESISTOR DIODES.

THE ABOVE EFFECT IS SIMILAR TO AN ODD PHENOMENON THIS MORNING WHILE RAMPING UP TO  $200\text{ A}$ . AT  $156\text{ A}$ , I LOST CONTROL OF THE VOLTAGE. WHEN I STOPPED TURNING THE CURRENT KNOB, THE VOLTAGE CONTINUED TO INCREASE ALMOST TO THE VOLTAGE LIMIT ( $2\text{ V}$ ) BEFORE SLOWLY FLOATING BACK DOWN TO SOMETHING REASONABLE. ARE THESE TWO EFFECTS RELATED? WHAT CAUSES THEM? WILL THEY BE PROBLEMATIC AT HIGHER FIELD?

—Mark Stevens

1/2/97 - pp

Jumpers across KM 8-5 + KM 9-6

- The magnet and p/s interlock circuit was re-wired such that all external (magnet) interlocks produce a slow discharge. A fast discharge can still be initiated by opening M4 and pressing either the "soop" or "Emergency Stop" buttons.

- Interlock response verification:

$$V_{LAP}-V_{LAN} = +7\text{ mV}, -7\text{ mV}$$

$$V_{LBP}-V_{LN} = +7\text{ mV}, -7\text{ mV}$$

$$V_{MAP}-V_{MAN} = +1.20\text{ V}, -0.78\text{ V}$$

$$V_{MAN}-V_{MAN} = +1.18\text{ V}, -1.82\text{ V}$$

All parameters are tested with power supply on (M3 + M4 closed) and all indicated a slow change.

Helium level trip verified to operate O.K. + initiates a slow discharge

- Lead flow Newport meters were modified to produce a fault on low and high flows. These faults produce a slow discharge (verified to be O.K.). A slow discharge is produced when :

$$405\text{ LPM} > \text{Lead A} > 90\text{ SCFM}$$

$$405\text{ LPM} > \text{Lead B} > 90\text{ SCFM}$$

- Verified that local "Stop" and "Emergency Stop" open M3, and the M4 switch will open M4 when switched to "Fast" discharge

- Turned on p/s to 100A @ 1:00 P.M. + set until 3:15 p.m.  
- Initiated a slow discharge from 100A.

- Set I to 200A (manually) @ 3:30 P.M. - reached target value at 3:45 P.M.  
- Initiated slow discharge @ 4:20 P.M.

- Set I to 300A manually + initiated slow discharge @ 5:45 P.M.  
265A → 245A; 12.86 sec.

## Stain Gages

Dipole Test 1/2/97 - Dr. Bert Wang NOT Present										
		EM1			EM2			EM3		
	Current AMPS	SG1 micro-strain	SG1 Load Tons	Delta micro-strain	SG2 micro-strain	SG2 Load Tons	Delta micro-strain	SG3 micro-strain	SG3 Load Tons	Delta micro-strain
Data	0	0	0	0	127	0	0	58	0	0
1/2/97	100	0	0	0	127	0	0	57	0.684	-1
	200	0	0	0	127	0	0	57	0.684	0
New Data	300	0	0	0	127	0	0	57	0.684	0
1/3/97	400		0	0		1.512	-127		0	-57
	500		0	0		1.512	0		0	0
	600		0	0		1.512	0		0	0
	700		0	0		1.512	0		0	0
	800		0	0		1.512	0		0	0
	900	2.044	0			0	0		0	0
	1000	2.044	0			0	0		0	0
	1100	2.044	0			0	0		0	0
Total Strain	0.0073		0	0.012		-127	0.012			-58
	Current AMPS	SG1 micro-strain	SG1 Load Tons	Delta micro-strain	SG2 micro-strain	SG2 Load Tons	Delta micro-strain	SG3 micro-strain	SG3 Load Tons	Delta micro-strain

## Stain Gages

## Stain Gages


2 January 1997

CURRENT.	0000	0200	0400	0600	0800	0700	0800	0900	-1600
TIME	275.		1720						
STRAIN GAGE									
#1	000	000	000	000					
2	+127	+127	+127	+127					
3	+058	+057	+057	+057					
4	-043	-043	-044	-048					
5	-191	-191	-191	-191					
6	+017	+016	+016	+016					
7	-001	-001	-001	-001					
→	8	-181	-182	-192.	-205.				
9	+005	+005	+005	+005					
→	10	-138	-141	-155	-173				
#2	41	+058	+058	+058	+058				
2	+037	+036	+037	+037					
3	-190	-190	-189	-190					
4	-164	-165	-164	-164					
5	+112	+111	+112.	+112.					
6	-25	-026.	-026.	-025					

-240  
-230  
-220  
-210  
-200 R.  
-190 300R.  
-180

0 1 2 3 4 5 6 7 8 9 10  $\times 10^{-2}$

SG #8





## Stain Gages

54

## Stain Gages

## Stain Gages

3 Jan 1997



1/3/67

- Removed jumper wires from slow dump resistor in an attempt to reduce the oscillations seen yesterday
- Measured value of slow dump resistor only w/ Kelvin bridge:  $R_{SD} = 7.22 \text{ m}\Omega // 7.29 \text{ m}\Omega$
- Set  $I = 200\text{A}$ , noticed slow discharge
- Set  $I = 200\text{A}$ , noticed slow discharge
  - noticed lead flow, helium level spike on charge exp. - top fill valve closed once dispersed
  - noticed 2 spikes ~~on~~ on discharge - top fill valve closed once then opened
  - Q2 lead flow responds identically to Q1 lead flow
- Set  $I \rightarrow 300\text{A}$ , noticed slow discharge
- Set  $I \rightarrow 200\text{A}$ , noticed fast discharge.

1/6/67

- Set  $I \rightarrow 400\text{A}$ , noticed slow dumps
- Set  $I \rightarrow 500\text{A}$ .

1/8/67

Set  $I \rightarrow 600\text{A}$ , regulated @ approx. 12:00 A.M. discharge at ~~12:00~~  $\approx 2:45$  A.M.  
 @  $I=600\text{A}$ . NMR = 0.7316005 T - Stable to last digits over 1 minute.

1/9/67

Set  $I \rightarrow 200\text{A}$  w/ short installed across slow dump resistor. Let stabilize for  $\approx 15\text{ min}$ : NMR: ~~0.7316005~~ - 0.231

Strain gauge channel #::

1	0
2	128
3	58
4	-45
5	-151
6	16
7	-1
8	-183
9	5
10	-144

## Stain Gages

Dipole Test 1/6/97 - Dr. Bert Wang NOT Present										
		EM1			EM2			EM3		
Current	SG1	SG1	Delta	SG2	SG2	Delta	SG3	SG3	Delta	
AMPS	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	
Data	0	0	0	0	127	0	0	57	0	0
1/6/97	100	0	0	0	127	0	0	57	0	0
	200	0	0	0	127	0	0	57	0	0
New Data	300	0	0	0	127	0	0	57	0	0
1/6/97	400	0	0	0	127	0.012	0	57	0	0
	500	- 2	0	0	126	1.512	-127	52	0.684	0
	600		0	0		1.512		42	0.18	-57
	700		0	0		1.512		0	0	0
	800		0	0		1.512		0	0	0
	900		2.044	0		1.512		0	0	0
	1000		2.044	0		0		0	0	0
	1100		2.044	0		0		0	0	0
Total Strain	0.0073		0	0.012		-127	0.012			-57
Current	SG1	SG1	Delta	SG2	SG2	Delta	SG3	SG3	Delta	
AMPS	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	

## Stain Gages

## Stain Gages

	300R		600L				600R			
Delta	SG14	SG14	Delta	SG9	SG9	Delta	SG10	SG10	Delta	
micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	
0	-180	0	0	4	0	0	-137	0	0	
0	-184	0.0116	-4	4	0	0	-142	0.016	0	
-1	-192	0.0348	-8	5	0.003	1	-153	0.0512	0	
0	-197	0.0493	-5	5	0.003	0	-164	0.0864	0	
0	-220	0.0957	-23	5	0.012	0	-191	0.1376	0	
2	<del>-235</del>	<del>0.1510.5423</del>	220	4	0.003	-5	<del>-209</del>	<del>0.230.4736</del>	7.8	
	<del>-237</del>	<del>0.220.5423</del>			0.003			0.4736	10.1	
		0.5423			0.003			0.4736	12.3	
		0.5423			0.003			0.4736	15.5	
		0.5423			0.531			0.9184	16.15	
		0.5423			0.531			0.9184	16.75	
		0.5423			0.531			0.9184	17.185	
1	0.0029		180	0.003		-4	0.0032		95.785	
Delta	SG14	SG14	Delta	SG9	SG9	Delta	SG10	SG10	Delta	
micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	micro-strain	Load Tons	micro-strain	

1/6/96

NO DATA.

CURRENT	000	100	200	300	400	500	600	700	800	900	1000		STRAIN
TIME		1030		1055	1205								GAGE
GAGE	(1215)			(1715)	(1105)	(720)							
1#1	000	000	000	000	000	-002							EM1
2	127	187	187	127	127	126							2
3	57	57	57	57	57	52							3
4	-43	-43	-44	-50	-52	-54							4
5	-191	-191	-191	-191	-191	-191							300L
6	17	17	17	16	16	15							6
7	-1	-1	-2	-2	-2	-2							7
8	-180	-184	-192	-197	-220	-235							300R
9	(-171)	4	5	(-210)	(-201)	(209)							600L
10	-137	-142	-153	-164	-191	-209							600R
	(-132)		(-78)	(-173)	(-173)								
2#1	58	58	58	58	59	58							5
2	37	37	37	36	37	36							8
3	-189	-189	-190	-190	-189	-190							100
4	-163	-163	-164	-164	-164	-165							200
5	112	112	111	111	112	111							400
6	-25	-25	-25	-26	-26	-26							500

ABOVE WITH SLOW RESISTOR (DUM 0). INSSACCO.

BELOW WITH SLOW RESISTOR DUM 0. SHUTTED OFF.

1/7/97. TUESDAY

1/8/97 WED

600A

afternoon 1/2 hrs  
powered.

	000	100	200	300	400	500	600	700	800	900	1000	
1			000			-002	-6					
2			127			126	141					
3			57			52	42					
4			-45			-54	-59					
5			-191			-191	-191					
6			16			16	6					
7			-2			-1	-1					
8			-196			-227	-176					
9			5			4	3					
10			-160			-200	-146					
			58			57	58					
1			37			37	36					
2			-189			-191	-190					
3			-164			-165	-165					
4			111			110	110					
5			-23			-25	-22					
TOTAL			11008			10357	1435					

## Hadron Dynapower Operational Modifications

James Proffitt 19-Sep.-1997

- ✓ 1. SW3: Force wiring to "remote" condition and remove switch
- ✓ 2. PLC TTL input module, slot 5:
  - Channel 2: Disconnect wire #200 and jumper input to COM (disable remote stop command).
  - Channel 3: Disconnect wire #201 and jumper input to COM (remote voltage sense).
  - Channel 4: Disconnect wire #202 and jumper input to COM (remote current sense).
- ✓ 3. On regulator module:
  - Remove relays CR1, CR2, CR3, CR4, CR5.
  - Install jumpers in CR1 and CR5 sockets to force circuit to use remote current feedback.
  - Install jumpers in CR2 socket to force circuit to use local error amplifier.
  - Install jumpers in CR3 socket to force circuit to use local voltage reference and remote current reference.
  - Install jumpers in CR4 socket to force circuit to use remote voltage feedback.
- ✓ 4. Connect remote voltage feedback cable from power supply regulator to magnet current lead flags through 1Kohm, 1/2w resistors to be located at the magnet.
- ✓ 5. Remove remote voltage reference 12-bit DAC, interconnecting cable, and wiring module.
- ✓ 6. Modify M3/M4 to be independent of PLC
  - Disconnect relays CR6, CR7, CR8, CR9 from the PLC DC output module in slot 4.
  - Wire CR6 to drive M3 and M4 such that M3 is open and M4 is closed when de-energized, and M3 is closed and M4 is open when energized.
  - Use the auxiliary contacts on M2 to drive CR6.
  - Connect the CR6 coil voltage to the STD-Bus digital input module, Channel 1.
  - Place 535 MCM jumpers from output terminal B+ to output terminal A- (as indicated on schematic) such that when M4 closes, the magnet is shorted and current flows through the ZFCT.


INSTALLED OCTOBER 1997  
Mark Stevens

## Hadron Dipole Protection Circuit Modifications


James Proffitt 19-Sep.-1997

The objective is to make all faults (except quench and lead voltage faults) initiate a controlled discharge through the STD-bus computer. Quench and lead voltage faults continue to affect the undervoltage release on M3. The main input power relay is latched on after startup to prevent the power supply from automatically turning off under any circumstances. The local power switch and emergency stop switch remain effective.

- ✓ 1. Remove KCR-1 and KCI-1 contacts from KM circuit.
- ✓ 2. Remove KCR-2 contacts from emergency stop circuit.
- ✓ 3. Remove CR4 and CR5 contacts from M3 undervoltage trip circuit.
- ✓ 4. Add relay KP to Dynapower and install KP contacts in "emergency stop" circuit and in "cryogenics ready" LED circuit.
- ✓ 5. Add install KM contacts in series with "Emergency Stop" circuit.
- ✓ 6. Connect KCR contacts to STD-bus digital input module.



- 7. Install process meter to interlock M3 undervoltage disconnect with magnet voltage. Monitor magnet voltage at current lead flags through 1Kohm, 1/2w resistors. Set interlock threshold to +/- 150% of the power supply charging voltage.



- ✓ 8. Remove Wang quench detector fault from KM circuit and install new quench detector fault into KP circuit.

*INSTALLED OCTOBER 1997*

*James Proffitt*

62

CO  
T  
G  
L

2

C  
I

2 -  
2  
4  
5  
6

1-23-97.

THURSDAY  
WEDNESDAY

63

Rate	0.2 AMPS/SEC											USING	ELECTRON	REVIEWER
CURRENT	000	100	200	300	400	500	600	700	800	900	1000	1100		
TIME	1000	1017	1030	1047	1117	1130	1145							
GAGE														
1 # 1	+1	0	0	0	0	0	0	-4						
2	+126	+126	+126	+126	+126	+125	+125	+134						
3	+58	+58	+58	+58	+58	+57	+54	+68						
4	-41	-43	-43	-48	-51	-53	-54							
5	-191	-191	-191	-191	-191	-191	-191	-191						
6	+17	+16	+16	+15	+16	+15	+15	+13						
7	0	0	0	0	0	0	0	0						
8	-181	-184	-184	-206	-198	-231	-231	-240						
9	+5	+5	+5	+5	+5	+4	+4	+5						
10	-131	-143	-157	-174	-169	-204	-204	-211						
2 1	+56	+59	+59	+59	+58	+59	+59	+58						
2	+34	+36	+36	+37	+36	+37	+36							
3	-191	-188	-188	-188	-189	-188	-189							
4	-165	-163	-163	-163	-164	-163	-163							
5	+111	+113	+113	+113	+112	+113	+113							
6	-26	-24	-24	-24	-26	-25	-25	-24						
7	-	-	-	-	-	-	-	-						

CURRENT	000	100	200	300	400	500	600	700	800	900	1000	1100		
TIME	1440		1507	1525	1538	1550	1600							
1 - 1	-1		0	-1	-2	-6	-9							
2	+125		+126	+125	+124	+131	+140							
3	+55		+56	+54	+51	+46	+40							
4	-44		-48	-52	-53	-55	-57							
5	-191		-191	-192	-192	-192	-192							
6	+16		+16	+15	+15	+13	+6							
7	-		0	-1	-1	-2	-1							
8	-180		-208	-209	-234	-252	-273							
9	+4		+5	+4	+4	+3	+3							
10	-135		-175	-179	-206	-223	-242							
2 - 1	+57		57	+56	+56	+56	+57							
2	+35		35	+35	+35	+35	+34							
3	-190		-190	-190	-190	-190	-189							
4	-164		-164	-164	-164	-165	-165							
5	+111		+111	+111	+111	+111	+111							
6	-25		-26	-26	-26	-25	-24							

1/29/98

INSTALLED POWER FACTOR CORRECTING CAPACITORS  
AND VERIFIED THAT THE POWER SUPPLY COULD  
BE TURNED ON AND RAMPED (TO 100 AMPS).

INSTALLED THE BEST UNITY/I 3 PHASE  
UNINTERRUPTIBLE POWER SUPPLY. POWER-UP  
SEQUENCE FOLLOWS. LANDED BATTERY BANK CABLES  
AND TORQUED THEM IN ACCORDANCE WITH MANUFACTURERS  
SPECIFICATION.

TYPICAL, Normal		Normal	
12 A	N-12	220 A	C-12
EP-0	012	95 A	021 A
85-8	18	85-8	71-8
70-8	28	200 A	25-8
95-2	115	85-2	545-2
45-3	25	45-3	75-3
65-3	25	65-3	45-3
55-3	25	55-3	35-3
35-3	25	35-3	25-3
25-3	25	25-3	15-3
15-3	25	15-3	15-3
85-5	25	85-5	85-5

**UT310, UT315, UT320, and UT330  
Planning and Installation Manual**

- **Dispose of Batteries Properly:** For assistance, call BEST's Technical Support Center at 1-800-356-5737 (U.S.A. or Canada) or call your local BEST office.

**! WARNING!**

Do not dispose of batteries in a fire because the batteries could explode.

Do not open or mutilate batteries. Released electrolyte is harmful to the skin and eyes and may be toxic.

Batteries contain lead. Many state and local governments have regulations about disposing of used batteries. Dispose of batteries properly. For assistance, call BEST's Technical Support at 1-800-356-5737 or call your local BEST office.

PERFORMED 1/30/98 - *Mark A Stevens*

## Section 300: Initial Startup and Phase Check

**! WARNING!**

Some units have been programmed at the factory for "autostart." If programmed for "autostart," the unit will turn on **any time** mains (AC line) is applied (after a 60-second delay). For more information or to change this feature, see the user manual.

Before continuing, read the warnings on the inside front cover of this manual.

After installing the unit, use this section to perform the initial startup and the phase check for the maintenance bypass cabinet (MBC). This section is for the **initial startup** only.

The steps in this section are for a unit with a BEST-supplied maintenance bypass cabinet (MBC).

**Follow this Procedure Exactly! No Load Should Be Connected!**

1. Make sure that all AC and DC power is off. ✓
2. Switch the UPS bypass switch to "UPS." ✓
3. Make sure that the main circuit breaker in the load panel is off so that the loads cannot receive power from the UPS. ✓


**UT310, UT315, UT320, and UT330  
Planning and Installation Manual**

4. Open the UPS front door(s). ✓
5. Remove the retaining brackets for the fuse holder containing DC fuses F001, F002, and F003. See Figure 3 or 5 in Section 201 for location of fuse holder.
6. At the mains AC input panel, switch on the input power to the UPS and maintenance bypass cabinet (MBC).
7. Switch the UPS AC disconnect switch "ON." The UPS display should show System type xxkVA xxxV, and an audible alarm should sound.
8. Within 20 seconds, the display should show \*\*Stand-by\*\*. ✓
9. Check the phase rotation at the service panel and the unit. The unit will not start if the phase rotation is incorrect. **The phase rotation must be A, B, C and clockwise.** ✓
10. When the audible alarm stops, push the green "on" button located inside the UPS front door. The display will show Normal operation load power xx%. ✓

**NOTE:** One or more alarms may occur. If the alarm(s) persists for more than 20 seconds, refer to the "Alarms" section of the user manual. If the unit activates a "battery monitor alarm," you should set the user parameter "battery monitor reset" to "ON." ✓

11. Open DC fuse holder (F001, F002, F003). See Figure 13. For location of DC fuse holder, see Figure 3 or 5.
12. Place the DC fuses in the fuse holder. Make sure that the red tab on the fuse faces the top of the fuse holder. Make sure that the fuse locking tabs are aligned in the slots on the fuse holder. See Figure 13.
13. Press each fuse into place. The fuse will "click" into place when it is locked in correctly. ✓

**Figure 13: DC Fuse Holder**



**UT310, UT315, UT320, and UT330  
Planning and Installation Manual**

- 14. Using an open palm, close the fuse holder. ✓
- 15. If the unit has external batteries:
  - a. Turn the pre-charge/discharge switch to the "pre-charge" position and hold it until the LED turns off.
  - b. Switch the battery DC disconnect (DCD) "ON." ✓
- 16. If the UPS is connected to a generator, verify that the unit operates properly on generator power before continuing. If the UPS operates properly on generator power, continue this procedure. If the UPS does not operate properly on generator power, phone BEST's Technical Support Center for assistance.

**⚠ CAUTION**

Before you switch the UPS bypass switch from "UPS" to "LINE", use the steps below to check for correct voltage, phasing, and system operating mode.

- 17. Program the unit into static bypass operation:
  - a. Press  to access the user parameters. ✓
  - b. Press the  or  key until the display shows Bypass operation: OFF. ✓
  - c. Press  to turn static bypass operation on. The display should show Bypass operation. ✓
- 18. At the maintenance bypass cabinet (MBC), make sure the UPS output voltage is approximately the same as the AC line input voltage (there may be slight differences). Use a true RMS voltmeter to measure the phase-to-neutral voltage at the MBC AC line input and the MBC output: ✓

MBC AC Line Input	MBC Output
a. L1 to neutral <u>279.2</u> VAC	L1 to neutral <u>283.0</u> VAC
b. L2 to neutral <u>278.6</u> VAC	L2 to neutral <u>281.8</u> VAC
c. L3 to neutral <u>278.0</u> VAC	L3 to neutral <u>281.1</u> VAC

The voltages in the first column should be similar to the voltages in the second column. If the voltages are more than 10 volts apart for 208 V nominal or 25 volts apart for 480 V nominal, check the connections and correct any wiring problems before continuing. ✓

**UT310, UT315, UT320, and UT330  
Planning and Installation Manual**

19. At the maintenance bypass cabinet (MBC), make sure the UPS output voltage and the AC line input voltage are in phase. To do this, measure the AC voltages between the following points at the MBC AC line input and the MBC output:

**MBC AC****Line Input**

- a. *L1 input*
- b. *L2 input*
- c. *L3 input*

**MBC Output**

- |           |                  |                 |
|-----------|------------------|-----------------|
| <i>to</i> | <i>L1 output</i> | <u>4.35</u> VAC |
| <i>to</i> | <i>L2 output</i> | <u>4.14</u> VAC |
| <i>to</i> | <i>L3 output</i> | <u>3.40</u> VAC |

**These readings must not be more than 10 VAC.** If they are, call BEST's Technical Support Center or your local BEST office. ✓

20. At the maintenance bypass cabinet (MBC), measure the following:

- a. *N input to Ground* .01 VAC
- b. *N output to Ground* .000 VAC
- c. *N input to N output* .01 VAC

"*N input to N output*" should not exceed "*N input to Ground*." If it does, call BEST's Technical Support Center. ✓

21. Check for proper voltages at the bypass switch load output terminals and the load distribution panel(s).

**Bypass Switch Load Output**

- a. *L1 to neutral* 283 VAC
- b. *L2 to neutral* 281.8 VAC
- c. *L3 to neutral* 280.9 VAC

**Load Panel Input**

- L1 to neutral* \_\_\_\_\_ VAC
- L2 to neutral* \_\_\_\_\_ VAC
- L3 to neutral* \_\_\_\_\_ VAC

*DO NOT CHECK*

22. Switch the UPS bypass switch to "BYPASS."

23. Recheck for proper voltages at the bypass switch load output and the load distribution panel(s). ✓

**Bypass Switch Load Output**

- a. *L1 to neutral* 279.2 VAC
- b. *L2 to neutral* 278.4 VAC
- c. *L3 to neutral* 277.9 VAC

**Load Panel Input**

- L1 to neutral* \_\_\_\_\_ VAC
- L2 to neutral* \_\_\_\_\_ VAC
- L3 to neutral* \_\_\_\_\_ VAC

*DO NOT CHECK*

24. Switch the UPS bypass switch to "UPS."

**UT310, UT315, UT320, and UT330  
Planning and Installation Manual**

25. Return the UPS to normal operation mode:

- a. Press  to access the user parameters.
- b. Press the  or  key until the display shows Bypass operation: ON.
- c. Press  to turn static bypass operation off. The display should show Normal operation load power xx%.

You can now apply loads to the system. As the last step of the installation, BEST recommends that you clear the events log. See Section 400, "Clearing the Events Log."

---

## Section 400: Clearing the Events Log

---

The events log contains the 250 most recent UPS events, including alarms. To clear the events log, follow the steps below:

1. Simultaneously press  and . The display should show Key in password.
2. Using the key pad, enter "920701." The display should show Logging stack is reset. The events log is now cleared.
3. Press . The display should show Normal operation load power xx%.

If the unit will not be used immediately, go to Section 500, "Shutdown Procedure."

1/31/98

WE PERFORMED A TEST OF THE UPS "BATTERY OPERATION" OUTPUT, A DISCRETE OUTPUT OF THE EXTERNAL CONNECTION BOARD. THE ADVERTISED 30 SEC. DELAY IS THERE, AND IT RESETS WITHOUT TRIPPING. IT OPERATES THE WAY WE WANT IT TO FOR USE AS A RAMP-DOWN COMMAND TO THE POWER SUPPLY. I AM INSTALLING AN INTERLOCK THROUGH THE LAST AVAILABLE CHANNEL OF THE PROTECTION SYSTEM RELAY CHASSIS, TO SEND THE POWER SUPPLY A "POWER-LOSS RAMP DOWN COMMAND". WITH THE 30 SECOND DELAY FROM THE UPS, THE CIRCUIT SHOULD IGNORE MINOR TRANSIENTS AND BE IMMUNE TO NUISANCE RAMP-DOWNS.

3/18/04

HADRON DIPOLE PROTECTION CIRCUIT TESTS  
PERFORMED SUBSEQUENT TO MAINTENANCE  
(INSTALLATION OF NEW LEAD FLAG HEATERS)

QUENCH VOLTAGES

1. ULAP - UMAN LOOP
2. VLBN - VLBP LOOP
3. UMAP - UMAN LOOP
4. UMAN - UMBN LOOP