

Certificate of Compliance

Certificate: 1253453 (LR 114789-1)
Project: 1253453
Issued to: American Power Conversion Corp.
801 Corporate Centre Drive
St. Charles, MO 63304-8685
USA
Attention: Mr. Ted Eckert

Master Contract: 190729
Date Issued: November 8, 2001

The products listed below are eligible to bear the CSA Mark shown



Issued by:

John N. Stedman
John N. Stedman

Authorized by:

Ray Fadavi
Ray Fadavi, P.Eng., MBA
Operations Manager

PRODUCTS

CLASS 3862 07 - INFORMATION TECHNOLOGY EQUIPMENT - Including Electrical Business Equipment

Part A: Switchable Receptacles, Models AP95 105 15 or PM20-5-15, rated 115V ac, 50/60Hz, 12A output; the control circuit is 115V ac, 50/60Hz, 24mA.

Part B: Switchable Receptacles, Models AP95 10520 or PM20-5-20, rated 115V ac, 50/60Hz, 16A output; the control circuit is 115V ac, 50/60Hz, 24mA.

Part C: Switchable Receptacle, Models AP9510L630 and PM20-6-30, rated 240V ac, 50/60Hz, 24Amps, 1Ph output; The control circuit is 115V ac, 50/60Hz, 48mA.

Part D: Switchable Receptacle, Model AP9510L620, rated 240V ac, 50/60Hz, 16Amps, 1Ph output; The control circuit is 115V ac, 50/60Hz, 48mA.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2No. 950-95

Safety of Information Technology Equipment, Including Electrical Business Equipment