

Gen ERR charge item 6: Radiation and Shielding

Eric Fuchey
University of Connecticut

October 22nd, 2020

*Are the radiation levels expected to be generated in the hall acceptable?
Is any local shielding required to minimize the effects of radiation in the equipment?*

To address this, we need:

- * **Evaluation of radiation budget for G_E^n**
- * **Evaluation of beam induced background in the individual detectors for G_E^n**

Radiation budget for GEN

Preliminary estimation of radiation budget for GEN by P. Degtiarenko

Hall: A		<u>RADIATION BUDGET FORM</u>								page: 1 of 1
Exp. # GEN		rev: 0		run dates: TBD				name of liaison: Todd Averett		
E12-09-016										
setup number		1	2	3	4	5	6	7	totals:	
beam	energy	GeV	4.4	4.4	4.4	4.4	4.4	6.6	8.8	
	current	uA(CW)	60.0	60.0	60.0	5.0	60.0	60.0	60.0	
exp't target	element		He-3	N	H	C	He-3	He-3	He-3	
	thickness	mg/cm2	90	70	60	280	90	90	90	
add'l target 1	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm2	46.9	46.9	46.9	46.9	46.9	46.9	46.9	
add'l target 2	element		N	N	N	N	N	N	N	
	thickness	mg/cm2	24.65	24.65	24.65	94.55	24.65	24.65	24.65	
cryo tgt window	element		Al	Al	Al		Al	Al	Al	
	thickness	mg/cm2	38.6	38.6	38.6		38.6	38.6	38.6	
exit window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm2	93.8	93.8	93.8	93.8	93.8	93.8	93.8	
time	run time (100% eff.)	hours	10	10	10	10	41	165	929	1175
		days	0.4	0.4	0.4	0.4	1.7	6.9	38.7	49.0
	installation time	hours								0
		days	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
dose rate at the fence post (run time)	method 1	urem/hr	0.55	0.52	0.39	0.09	0.55	0.63	0.69	
	method 2	urem/hr								
	conservative	urem/hr	0.55	0.52	0.39	0.09	0.55	0.63	0.69	
dose per setup		urem	6	5	4	1	23	104	643	784.6
% of annual dose budget		%	0.1	0.1	0.0	0.0	0.2	1.0	6.4	7.846
% of allowed dose for the total time										58.5
% of allowed dose for the run time only										58.5
<i>If > 200%, discuss result with Physics Research EH&S officer</i>										

date form issued:

October 15, 2020

authors: P.Degtiarenko


Radiation budget for GEN

Using same material thicknesses, my rough estimations and Pavel's simulation results are in rough agreement; My numbers are slightly higher

setup number			1	2	3	4	5	6	7	<i>totals:</i>
beam	energy	GeV	4.4	4.4	4.4	4.4	4.4	6.6	8.8	
	current	$\mu\text{A (CW)}$	60.0	60.0	60.0	5.0	60.0	60.0	60.0	
exp't target	element		3He	N	H	C	3He	3He	3He	
	thickness	mg/cm^2	97	904	65	280	97	97	97	
add'l target	element		N	N	N	N	N	N	N	
	thickness	mg/cm^2	26	26	26	97.8	26	26	26	
cryo tgt window	element		Al	Al	Al		Al	Al	Al	
	thickness	mg/cm^2	83	83	83		83	83	83	
entrance window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm^2	46.9	46.9	46.9	46.9	46.9	46.9	46.9	
	element		Al	Al	Al	Al	Al	Al	Al	
	thickness	mg/cm^2	1.4	1.4	1.4	1.4	1.4	1.4	1.4	
exit window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm^2	93.9	93.9	93.9	93.9	93.9	93.9	93.9	
	element		Al	Al	Al	Al	Al	Al	Al	
	thickness	mg/cm^2	1.4	1.4	1.4	1.4	1.4	1.4	1.4	
	run time	hours	10	10	10	10	41	165	929	1175
	installation	hours								0
	time	days	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
dose rate at the fence post (run time)	method 1	$\mu\text{rem}/\text{hr}$	0.88	3.24	0.73	0.12	0.88	0.98	1.06	
	method 2	$\mu\text{rem}/\text{hr}$								
	conservative	$\mu\text{rem}/\text{hr}$	0.88	3.24	0.73	0.12	0.88	0.98	1.06	
dose per setup		μrem	9	32	7	1	36	161	985	1231
% of annual dose budget		%	0.1	0.3	0.1	0.0	0.4	1.6	9.8	12.3%
% of allowed dose for the total time										91.7%
% of allowed dose for the run time										91.7%


Table 1: Estimated radiation budget for GEN. Radiation rate numbers are taken from the GMn E12-09-019 radiation budget form and rescaled by luminosity and material thicknesses.

GEn geometry implementation in G4SBS




GEn geometry implementation in G4SBS

Fully detailed target geometry: helmholtz coils, target ladder, collimators



Detector rates / occupancies: GEMs



Background in GEMs for GEn 10.18 GeV² with target collimators comparable to GMn 13.5 GeV² with full beam line shielding.


From the studies made with GMn:

- Such rates are manageable for the tracking
- GEM occupancies at 100 kHz/cm²: * 25-30% with only zero suppression;
* 10-15% with pulse shape selection;

Detector rates / occupancies: GEMs


Origin of GEM background:

vertex of Origin track for GEM hits



Target area


projected z vertex at $x = 0$ for SD tracks for GEM hits



A significant fraction of the background does come from the downstream beam pipe and could probably be shielded.


Detector rates / occupancies: HCal

HCal, thr = 4.48e-03 GeV



Threshold of individual hits set to
1% of the sum average

HCal, PMT hit, Edep>4.5 MeV




Resulting rates: 300-500 kHz
=> Occupancy (100ns gate): 3-5%

PMTs anode currents: HCal

Anode current estimation: using the sum of **all** p.e. detected in the PMTs


HCal anode current, gain = $1.0e+05$



2-5 μA drawn: 2-5 mC drawn over GEn 10.18 GeV² alone


Detector rates / occupancies: BB Hodoscope

BBHodo, thr = 1.91e-03 GeV



Threshold of individual hits set to
2% of the sum average

BB Hodo PMT hit, Edep >= 1.9 MeV




Resulting rates: 200-500 kHz
=> Occupancy (100ns gate): 2-5%

PMTs anode currents: BB Hodoscope

Anode current estimation: using the sum of **all** p.e. detected in the PMTs


BB Hodo anode current, gain = 1.0e+04



1-3 µA drawn: 1-3 mC drawn over GEn 10.18 GeV² alone


Detector rates / occupancies: BB PS

BBPS, thr = 1.54e-02 GeV



Threshold of individual hits set to 2% of the sum average

BB PS PMT hit, $E_{dep} \geq 15.4$ MeV




Resulting rates: 300 kHz - 2 MHz
=> Occupancy (100ns gate): 3-20%

PMTs anode currents: BB PS

Anode current estimation: using the sum of **all** p.e. detected in the PMTs


BB PS anode current, gain = 1.0×10^5



1-2 μA drawn: 1-2 mC drawn over GEn 10.18 GeV² alone


Detector rates / occupancies: BB SH

BBSH, thr = 2.35e-02 GeV



Threshold of individual hits set to 1% of the sum average


BB SH PMT hit, Edep > 23.5 MeV



Resulting rates: 100-200 kHz
=> Occupancy (100ns gate): 1-2%

PMTs anode currents: BB SH


Anode current estimation: using the sum of **all** p.e. detected in the PMTs



0.2 - 1 μA drawn: 0.2 - 1 mC drawn over GEn 10.18 GeV2 alone

Detector rates / occupancies: GRINCH

Background rate in GRINCH





Resulting rates: 100-200 kHz

=> Occupancy (100ns gate): 1-2%

Number of PMTs low enough that current drawn is
not a concern

Dose rate in BB PS/SH



Dose rate around 3 Rad/h for BB PS. BBPS blocks changed for GMn, to withstand higher does rates.

Summary and outlook

Are the radiation levels expected to be generated in the hall acceptable?

The current radiation budget estimations show that GEN should use at most 12.3% of the radiation budget, and less than 100% of the budget allowed for the running period.

The estimations are not finalized, but the worse estimation should be conservative.

Is any local shielding required to minimize the effects of radiation in the equipment?

The background levels in the equipment are acceptable and should not significantly affect their performances

However, our simulations show that we might achieve a further reduction of the background levels by shielding the BigBite detector from the beam line.

Backup