

Gen ERR charge item 6: Radiation and Shielding

Eric Fuchey
University of Connecticut

October 22nd, 2020

*Are the radiation levels expected to be generated in the hall acceptable?
Is any local shielding required to minimize the effects of radiation in the equipment?*

To address this, we need:

- * **Evaluation of radiation budget for G_E^n**
- * **Evaluation of beam induced background in the individual detectors for G_E^n**

Radiation budget for GEn

Estimation of radiation budget for GEn by P. Degtiarenko

Hall: A			<u>RADIATION BUDGET FORM</u>							page: 1 of 1
Exp. # GEn		rev: 0	run dates: TBD				name of liaison: Todd Averett, Eric Fuchey			
E12-09-016										
setup number			1	2	3	4	5	6	7	
beam	energy	GeV	4.4	4.4	4.4	4.4	4.4	6.6	8.8	<i>totals:</i>
	current	uA(CW)	60.0	60.0	60.0	5.0	60.0	60.0	60.0	
exp't target	element		He-3	N	H	C	He-3	He-3	He-3	
	thickness	mg/cm2	97	904	65	280	97	97	97	
add'l target 1	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm2	46.9	46.9	46.9	46.9	46.9	46.9	46.9	
add'l target 2	element		Al	Al	Al	Al	Al	Al	Al	
	thickness	mg/cm2	2.8	2.8	2.8	2.8	2.8	2.8	2.8	
add'l target 3	element		N	N	N	N	N	N	N	
	thickness	mg/cm2	26	26	26	97.8	26	26	26	
cryo tgt window	element		Al	Al	Al		Al	Al	Al	
	thickness	mg/cm2	83	83	83		83	83	83	
exit window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm2	93.9	93.9	93.9	93.9	93.9	93.9	93.9	
time	run time (100% eff.)	hours	10	10	10	10	41	165	929	1175
		days	0.4	0.4	0.4	0.4	1.7	6.9	38.7	49.0
	installation time	hours								0
		days	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
dose rate at the fence post (run time)	method 1	urem/hr	0.68	2.91	0.50	0.09	0.68	0.77	0.85	
	method 2	urem/hr								
	conservative	urem/hr	0.68	2.91	0.50	0.09	0.68	0.77	0.85	
dose per setup		urem	7	29	5	1	28	128	787	983.8
% of annual dose budget		%	0.1	0.3	0.1	0.0	0.3	1.3	7.9	9.838
% of allowed dose for the total time										73.34
% of allowed dose for the run time only										73.34
<i>If > 200%, discuss result with Physics Research EH&S officer</i>										

date form issued:


October 19, 2020

authors: P.Degtiarenko

<10% of annual dose budget
 <100% of allowed dose for the period




GEn geometry implementation in G4SBS




GEn geometry implementation in G4SBS

Fully detailed target geometry: helmholtz coils, target ladder, collimators



Detector rates / occupancies: GEMs



Background in GEMs for GEn 10.18 GeV² with target collimators comparable to GMn 13.5 GeV² with full beam line shielding.

From the studies made with GMn:

- Such rates are manageable for the tracking
- GEM occupancies at 100 kHz/cm²: * 25-30% with only zero suppression;
* 10-15% with pulse shape selection;



Detector rates / occupancies:

PMT-based detectors

Average rates and occupancies in PMT based detectors.
Occupancies are evaluated assuming a 100 ns data acquisition window.

Detector	Threshold (MeV)	Average rate (kHz)	Occupancy (100 ns)
HCal	4.5	417	4.2 %
Hodoscope	1.9	293	2.9 %
Preshower	15.4	1095	11.0 %
Shower	23.5	152	1.5 %
GRINCH	-	54	0.5 %

Dose rate in BB PS/SH



Dose rate around 3 Rad/h for BB PS. BBPS blocks changed for GMn, to withstand higher does rates.

Summary and outlook

Are the radiation levels expected to be generated in the hall acceptable?

The current radiation budget estimations show that GEN should use at most 12.3% of the radiation budget, and less than 100% of the budget allowed for the running period.

The estimations are not finalized, but the worse estimation should be conservative.

Is any local shielding required to minimize the effects of radiation in the equipment?


The background levels in the equipment are acceptable and should not significantly affect their performances

However, we are still investigating the sources of background, in order to determine if a simple shielding design may provide a further reduction of the background levels in the BigBite detectors.

Backup


Detector rates / occupancies: HCal

HCal, thr = 4.48e-03 GeV



Threshold of individual hits set to
1% of the sum average


HCal, PMT hit, Edep > 4.5 MeV



Resulting rates: 300-500 kHz
=> Occupancy (100ns gate): 3-5%


Detector rates / occupancies: BB Hodoscope

BBHodo, thr = 1.91e-03 GeV



Threshold of individual hits set to
2% of the sum average


BB Hodo PMT hit, Edep >= 1.9 MeV



Resulting rates: 200-500 kHz
=> Occupancy (100ns gate): 2-5%


Detector rates / occupancies: BB PS

BBPS, thr = 1.54e-02 GeV



Threshold of individual hits set to 2% of the sum average


BB PS PMT hit, $E_{dep} \geq 15.4$ MeV



Resulting rates: 300 kHz - 2 MHz
=> Occupancy (100ns gate): 3-20%


Detector rates / occupancies: BB SH

BBSH, thr = 2.35e-02 GeV



Threshold of individual hits set to 1% of the sum average


BB SH PMT hit, Edep > 23.5 MeV



Resulting rates: 100-200 kHz
=> Occupancy (100ns gate): 1-2%

Detector rates / occupancies: GRINCH

Background rate in GRINCH



Resulting rates: 100-200 kHz


=> Occupancy (100ns gate): 1-2%

Number of PMTs low enough that current drawn is
not a concern

PMTs anode currents: HCal

Anode current estimation: using the sum of **all** p.e. detected in the PMTs

HCal anode current, gain = 1.0e+05




2-5 μA drawn: 2-5 mC drawn over GEN 10.18 GeV2 alone

PMTs anode currents: BB Hodoscope

Anode current estimation: using the sum of **all** p.e. detected in the PMTs

BB Hodo anode current, gain = 1.0e+04




1-3 µA drawn: 1-3 mC drawn over GEn 10.18 GeV² alone

PMTs anode currents: BB PS

Anode current estimation: using the sum of **all** p.e. detected in the PMTs


BB PS anode current, gain = 1.0e+05



1-2 μA drawn: 1-2 mC drawn over GEn 10.18 GeV2 alone

PMTs anode currents: BB SH

Anode current estimation: using the sum of **all** p.e. detected in the PMTs



0.2 - 1 μA drawn: 0.2 - 1 mC drawn over GEN 10.18 GeV2 alone

setup number			1	2	3	4	5	6	7	<i>totals:</i>
beam	energy	GeV	4.4	4.4	4.4	4.4	4.4	6.6	8.8	
	current	μA (CW)	60.0	60.0	60.0	5.0	60.0	60.0	60.0	
exp't target	element		3He	N	H	C	3He	3He	3He	
	thickness	mg/cm^2	97	904	65	280	97	97	97	
add'l target	element		N	N	N	N	N	N	N	
	thickness	mg/cm^2	26	26	26	97.8	26	26	26	
cryo tgt window	element		Al	Al	Al		Al	Al	Al	
	thickness	mg/cm^2	83	83	83		83	83	83	
entrance window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm^2	46.9	46.9	46.9	46.9	46.9	46.9	46.9	
	element		Al	Al	Al	Al	Al	Al	Al	
	thickness	mg/cm^2	1.4	1.4	1.4	1.4	1.4	1.4	1.4	
exit window	element		Be	Be	Be	Be	Be	Be	Be	
	thickness	mg/cm^2	93.9	93.9	93.9	93.9	93.9	93.9	93.9	
	element		Al	Al	Al	Al	Al	Al	Al	
	thickness	mg/cm^2	1.4	1.4	1.4	1.4	1.4	1.4	1.4	
	run time	hours	10	10	10	10	41	165	929	1175
	installation	hours								0
	time	days	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
dose rate at the fence post (run time)	method 1	$\mu\text{rem}/\text{hr}$	0.88	3.24	0.73	0.12	0.88	0.98	1.06	
	method 2	$\mu\text{rem}/\text{hr}$								
	conservative	$\mu\text{rem}/\text{hr}$	0.88	3.24	0.73	0.12	0.88	0.98	1.06	
dose per setup		μrem	9	32	7	1	36	161	985	1231
% of annual dose budget		%	0.1	0.3	0.1	0.0	0.4	1.6	9.8	12.3%
% of allowed dose for the total time										91.7%
% of allowed dose for the run time										91.7%

Table 1: Estimated radiation budget for GEn. Radiation rate numbers are taken from the GMn E12-09-019 radiation budget form and rescaled by luminosity and material thicknesses.